



# BULGARKONTROLA S.A.

**CARGO & DAMAGE SURVEYS, LABORATORY ANALYSES,  
CONFORMITY ASSESSMENT & TECHNICAL INSPECTIONS,  
MANAGEMENT SYSTEMS, ORGANIC CERTIFICATION**

Head office: 23, Sitnyakovo Blvd., 1506 Sofia, Bulgaria  
Emergency mobile: +359 889 400 400, Tel.: +359 2 989 4070, Fax: +359 2 988 2354  
E-mail: sales@bulgarkontrola.bg, cert@bulgarkontrola.bg

## CERTIFICATE OF CONFORMITY

**14 – НУРВСПСРБ – 3199**

Issued pursuant to Art. 14, par.1 and par. 2 of the Regulation № ПД-02-20-1 on 05.02.2015 on the terms and conditions for use of construction products in the construction of the Republic of Bulgaria on Ministry of Regional Development and Public Works for the **construction product**

### **HOT ROLLED PLAIN REINFORCING STEEL class B235 of bars and of coils**

**used for the reinforcement of concrete with nominal diameter**  
and evaluated characteristics in accordance with national requirements as per Supplement № 1 to this Certificate.

placed on the market by

**EFTCG SAN. A.Ş.**

Asiroglu Cad., №175, Çayirova-Gebze/Kocaeli, TURKEY

manufactured by

**EFTCG SAN. A.Ş.**

Asiroglu Cad., №175, Çayirova-Gebze/Kocaeli, TURKEY

This certificate certifies that the product has been evaluated  
and meets national requirements set out in

**BDS 4758: 2008**

*and Annex 3, item 1.1. to item 2 of Order № RD-02-14-1329 from 03.12.2015,  
the Minister of Regional Development and Public Works,  
Amendment and addition by Order № RD-02-14-590 from 05.07.2017*

The Certificate was issued on **01.02.2019**, cancel the Certificate № **14-НУРВСПСРБ-3078** on **05/02/2018** and remains valid to **04/02/2021**, the provided that the manufacturer ensures consistency of product characteristics and the conditions of production or production control have not been changed significantly.

Place: Sofia  
Date: 01/02/2019

Director of "Conformity Assessment" Dept.

/T. Lyubenova/

BULGARKONTROLA S.A.– Sofia with identification number 14 of register Ministry of Regional Development and Public Works Permit № ПООСН-14 on 15.09.2016, issued by Ministry of Regional Development and Public Works



**Annex № 1**  
**to Certificate of Conformity № 14– HYPBCIICPB-3199**

**1. Nominal diameter №: 6 / 6,5/ 8 /10 /12/14/16/18/20/22/25**

**2. Evaluated characteristics in accordance with national requirements**

<b>Characteristics</b>	<b>Requirement to declare / border level</b>
Yield strength, $R_e$	min 235 MPa According tabl. № 2 of BDS 4758:2008
Tensile strength, $R_m$	min 370 MPa According tabl. № 2 of BDS 4758:2008
Elongation $A_5$ , %	min 25 % According tabl. № 2 of BDS 4758:2008
Bending at $180^\circ$	without cracks According tabl. № 2 of BDS 4758:2008
Linear mass, kg / m	$0,222 \div 3,853$ According tabl. № of BDS 4758:20080
Cross-sectional area $A_n$ , mm	$28,3 \div 490,9$ According tabl. № 3 of BDS 4758:2008
Chemical composition Weldability (carbon equivalent), $C_{eq}$ , %	No requirements

**Place: Sofia**  
**Date: 01/02/2019**

**Director of "Conformity Assessment" Dept.**



*[Signature]*  
**/T. Lyubenova/**